

AnnexureD

BUILDING SAFETY CERTIFICATE

No. 1225

Dated: 16/7/2024

It is certified that the existing building **SHREE SANDIPANI INTERNATIONAL SCHOOL**
(RUN BY SHREENATH ASHIRWAD EDUCATION SOCIETY SAMITI) (name of the building
or premises) at HANSA KHEDI DHARMAT ROAD CHANDRAWATIGANJ TEHSIL
SANWER DIST. INDORE MADHYA PRADESH 453551

(address) is having block(s)/Floor(s) as per details below:

Detail of Block(s) in school	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in the Block	G+2	-	-	-	-	-

The building is owned/occupied by SHREE SANDIPANI INTERNATIONAL SCHOOL (RUN BY SHREENATH ASHIRWAD EDUCATION SOCIETY SAMITI) (name of the Institution) have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of P.W.D. DIVISION No.2 – INDORE (Name of Department/Govt.) on 16/07/2024 (date of inspection) in the presence of MR. SHASHIKANT PANDEY (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy for running school with effect from 18/07/2024 for a period of 17/07/2025 years in accordance

With rule and subject to compliance of the specific conditions as appended.

1. Ramp and railing provided for physically handicapped.
2. Staircase is 1.50 mts rise of steps is 0.15 and head is 0.50 mts
3. Ceiling height is 12 feet.
4. Paved lobby is available for fire engine to move smoothly in building.

Issued on 16/07/2024 at School Building by

* Strike out whichever is not applicable. In case of block is more than six use separate sheet for detail.

Signature with Seal :

Name : **Executive Engineer**

Designation : **P.W.D. Div. No. 2, Indore (M.P.)**

Name & Address of Department/Office: _____